



**NOTES:**

1. WARNING LABELS INCLUDED WITH EACH FIXTURE.
2. DUCT WALLS MAY BE LINED WITH HIGH SPECTRAL ALUMINUM TO ENHANCE UV-C ENERGY BY OTHERS.

**GENERAL:**

1. REFER TO PRODUCT IOM FOR INSTALLATION DETAILS.
2. USE INTERLOCK SWITCHES ON ALL ACCESSES TO LAMPS.
3. CAUTION: NEVER LOOK AT LAMPS WHEN LIT – EYE AND SKIN DAMAGE MAY RESULT FROM EXPOSURE.

**PARTS LIST**

'A' DIM	QTY	MODEL#	PART #	DESCRIPTION	DUCT	
					'B' DIM	'C' DIM
33		RLM-33-HO-EL-120/277	55886551	RLM 33" SINGLE ENDED - HO -ENCAPSULAMP - 120/277VAC (75W LAMP)		
61		RLM-61-HO-EL-120/277	55886551	RLM 61" SINGLE ENDED - HO -ENCAPSULAMP - 120/277VAC (145W LAMP)		



PO BOX 800370  
 SANTA CLARITA, CA 91380 USA  
 Ph.: 877.884.4822 FAX: 877.794.1294

PROJECT NAME:		LOCATION:		LAMP WATTS PER SQUARE FOOT:	
CONTACT:		AHU TAG:		APPLICATION PRESSURE DROP:	
REP FIRM:		QUOTE NO:		CONTRACTOR:	
				DWG NO: 98000701	