



NOTES:

1. UL LISTED.
2. WARNING LABELS INCLUDED WITH EACH FIXTURE.

GENERAL:

1. REFER TO PRODUCT IOM FOR INSTALLATION DETAILS.
2. USE INTERLOCK SWITCHES ON ALL ACCESSES TO LAMPS.
3. CAUTION: NEVER LOOK AT LAMPS WHEN LIT - EYE AND SKIN DAMAGE MAY RESULT FROM EXPOSURE.

PARTS LIST					DUCT	
'A' DIM	QTY	MODEL#	PART #	DESCRIPTION	'B' DIM	'C' DIM
33	<input type="text"/>	RLM-33-HO-EL-120/277	55866551	RLM 33" SINGLE ENDED - HO -ENCAPSULAMP - 120/277VAC	<input type="text"/>	<input type="text"/>
61	<input type="text"/>	RLM-61-HO-EL-120/277	55886551	RLM 61" SINGLE ENDED - HO -ENCAPSULAMP - 120/277VAC	<input type="text"/>	<input type="text"/>



PO BOX 800370
 SANTA CLARITA, CA 91380 USA
 Ph.: 877.UV4.HVAC FAX: 877.794.1294

DRAWING NAME:

LOCATION:

LAMP WATTS PER SQUARE FOOT:

CONTACT:

AHU TAG:

ENGINEER:

APPLICATION PRESSURE DROP:

REP FIRM:

QUOTE NO:

CONTRACTOR:

TOTAL ELECTRICAL WATTS: