




INSTALLATION TEMPLATE

APPLY THIS TO DESIRED LOCATION

CAUTION: Before cutting hole, inspect location to prevent accidental cutting of wires or refrigerant pipes.




USE 2 7/8" HOLE SAW




Step 1 Use 2 7/8 inch hole saw – Cut hole for Mounting Ring

Step 2 Slide Mounting Ring into hole and secure with 3 screws (provided).


Step 3 Slide Locking Clip out Insert Power Supply/Lamp and twist clockwise.



Step 4 Once in position. Slide Locking Clip in



Step 5



Install Power Cap; Wire to 24V Power.

ELECTRICAL INPUT:
24V AC/DC 50/60Hz 1A

CAUTION: Use of other than labeled voltages will void product warranty and could cause damage to the entire system.



CAUTION: THE HORNET IS RATED AT 22VA. IT IS RECOMMENDED THAT THE ANTICIPATED 24V SOURCE BE CHECKED FOR ITS ABILITY TO SERVICE A 22VA LOAD. A SEPARATE TRANSFORMER IS RECOMMENDED



WARNING: AVOID EXPOSING UNPROTECTED EYES AND BARE SKIN TO UV-C

REPLACE LAMP ANNUALLY

REPLACEMENT LAMP P/N: 57033551 (EncapsuLamp P/N: 57035551)

www.HornetUV.com

UVR
UV RESOURCES

P/N: 57000090 Rev. B