



RECORD TEST RESULTS

DATE: _____

FACILITY: _____

ADDRESS: _____

CITY, STATE, ZIP: _____

GLO MODEL: _____

GLO LOCATION: *

GLO CONFIRMED MOUNTING HEIGHT: _____

TESTER NAME: _____

RADIOMETER MODEL: _____

NOTES: _____

* IT IS RECOMMENDED THAT PHOTOS BE TAKEN TO DOCUMENT GLO INSTALL

- NOTES:
1. REFER TO PRODUCT IOM FOR INSTALLATION DETAILS.
 2. FIXTURE BOTTOM MUST BE MOUNTED 7 FEET (84") OR HIGHER.
 3. CAUTION: ALWAYS WEAR SAFETY GLASSES WHEN TESTING.
 4. TEST FOR UV-C AT 71" - MUST BE BELOW 0.40W/cm²
 5. CAUTION: DO NOT OPERATE FIXTURE WITHOUT SAFETY SECURED.
 6. CAUTION: DO NOT LOOK INTO A LIT FIXTURE AT ANY TIME.
 7. CAUTION: TURN OFF AND UNPLUG FIXTURE BEFORE SERVICING.
 8. CAUTION: WEAR GOGGLES AND A FULL FACE MASK WHEN WORKING AROUND THIS UNIT.
 9. CAUTION: DO NOT LET ANY LIGHT STRIKE YOUR EYES WHEN DE-ENERGIZING.

OTHERWISE SPECIFIED, STANDARD TOLERANCE APPLIES

DEPT	APPROVAL	DATE
PROD		
ENGR / QA		

PROPRIETARY AND CONFIDENTIAL

THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF UV RESOURCES. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT WRITTEN PERMISSION IS PROHIBITED

REV	DATE	DESCRIPTION OF CHANGE	DFT
C	05/22/2025	UPDATED FORMAT	HAHN
B	7/24/2023	REVISED DIMENSIONS	
A	7/15/2020	ADDED ADDITIONAL TEST RECORDING CHART	
0	5/6/2020	FIRST ISSUE	

SCALE	NOT DRAWN TO SCALE	PAGE	1 OF 1
-------	--------------------	------	--------

DISTANCE (INCHES) $\mu\text{W}/\text{cm}^2$

UV R **UV RESOURCES**

DRAWING NO 98000179

GLO COMMISSIONING FORM

REV C